



ROMBLON STATE UNIVERSITY
BIDS AND AWARDS COMMITTEE

Community Outreach Center, RSU-Main Campus, Liwanag, Odiangan, Romblon 5505
 Telephone: (042) 567-5952
 Email: bac@rsu.edu.ph
 Website: rsu.edu.ph



Management System
 ISO 9001:2015



TECHNICAL SPECIFICATIONS
Solicitation No. RSU-2024-04-039
ABC: PhP440,000.00

Supply and Delivery of Water Tanks and Pumps for Romblon State University – San Agustin Campus

| ITEM NO. | UNIT | ITEM DESCRIPTION | QTY | STATEMENT OF COMPLIANCE ¹ |
|--------------|------|--|----------|--------------------------------------|
| 1 | Unit | Water Pump <ul style="list-style-type: none"> • Electric, Jet Booster Pump; • 2.0 HP; • Max Pressure – 70-80 PSI; • Volume Capacity – 110L per minute minimum • Max Head – 70 Meters • Pure copper motor, double impeller, thermal protector | 1 | |
| 2 | Unit | Submersible Pump <ul style="list-style-type: none"> • 2HP • 3450 RPM Minimum • Head – 14.5 meter minimum • Qmax – 20L per minute • Pure copper motor with 10-meter discharge hose (2” pipe) | 2 | |
| 3 | Unit | Water Tank <ul style="list-style-type: none"> • Horizontal, Cylindrical Water Storage Tank, Stainless Steel • 3000 Liters Capacity Minimum • 160 cm diameter minimum • 230cm length minimum • 170cm height minimum | 1 | |
| 4 | Unit | Steel Water Tank Tower, 5 meters high | 1 | |
| TOTAL | | | 5 | |

¹ [Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder’s statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]



ROMBLON STATE UNIVERSITY BIDS AND AWARDS COMMITTEE

Community Outreach Center, RSU-Main Campus, Liwanag, Odiangan, Romblon 5505
Telephone: (042) 567-5952
Email: bac@rsu.edu.ph
Website: rsu.edu.ph



Name and Signature of the Bidder/Authorized Representative

Name of the Company